

To: ALL BIDDERS

Ref: FSU Education Building – Nursing Simulation

Subj.: **ADDENDUM BULLETIN NO. 3**

This Addendum Bulletin shall be incorporated in the Construction Documents including the Drawings and Specifications for the Project referenced above. All work amended as listed herein shall be included in your Bid Proposal and the bidder shall acknowledge this addendum bulletin on the Bid Form.

FOR CLARIFICATION:

Addendum 2 – Item 1 BID DATE: FOR CLARIFICATION, Bid Date now **Tuesday April 1, 2025 @ 3:00pm.** Bid opening – Physical Plant Conference Room.

Addendum 2 – Item 2 LEED: FOR CLARIFICATION, Is this project pursuing LEED? – **No.**

Addendum 2 – Item 3 FSC Certification: FOR CLARIFICATION, FSC Certification is only listed in section 081416. Sections 064116 or 123623.13 do no mention regarding FSC. Please clarify there is no FSC requirement for the millworkers? – **No not required.**

Addendum 2 – Item 4 AWI QCP Labels: FOR CLARIFICATION, Section 064116 requires AWI QCP Labels, is this project registered, and will the millworkers need to be AWI QCP registered? – **No not registered.**

Addendum 2 – Item 5 AV Cabling/Connections: FOR CLARIFICATION, Please confirm if the AV Cabling/Connections for this project shall be Cat6 or Cat6A including patch cables for main headend server area? – **Cat6**

Addendum 2 – Item 6 Signage: FOR CLARIFICATION, Reference A6.0: please confirm sign type "R01" is intended for all new doors (will enlarge to include code-required pictogram at restrooms). – **Yes**

Addendum 2 – Item 7 Sonex Panels: FOR CLARIFICATION, Sonex Clean Wall Panels – **Acoustical Wall Panels are Basis of Design with No modifications. Product is not required to be tackable. Attachment method(s) provided by manufacturer are acceptable.**

FSU Education Building – Nursing Simulation
Omni Associates-Architects

Addendum No. 2

03/21/25

END OF ADDENDUM

Submitted by:
THE OMNI ASSOCIATES - ARCHITECTS

A handwritten signature in black ink, appearing to read 'Adam L. Rohaly', with a horizontal line extending from the end of the signature.

Adam L. Rohaly, AIA, NCARB, LEED AP BD+C
Principal in Charge