

Fire Safety Reporting: 2009

Date	Time	Building	Room/Area	Explanation
23-Jan	3:32 p.m.	Bryant	N/A	Scheduled Drill
7-Feb-09	8:40 p.m.	Bryant	N/A	Scheduled Drill
5-Mar-09	8:44 a.m.	Bryant	N/A	Scheduled Drill
28-Mar-09	11:10 p.m.	Bryant	315B	Hair Flat Iron
3-Apr-09	12:05 a.m.	Bryant	315 B	Hair Flat Iron
5-Apr-09	5:05 p.m.	Bryant	312	Shower Steam
15-Apr-09	11:00 a.m.	Bryant	213	Smoking
18-Apr-09	5:40 a.m.	Bryant	301	Shower Steam
22-Apr-09	12:25 a.m.	Bryant	N/A	Scheduled Drill
5-May-09	1:47 a.m.	Bryant	2nd Floor	Pull Station Activated
10-May-09	9:45 p.m.	Bryant	N/A	Scheduled Drill
12-May-09	12:10 a.m.	Bryant	4th Floor	Pull Station Activated
23-Aug-09	10:50 p.m.	Bryant	2nd Floor	Pull Station Activated
4-Sep-09	7:12 a.m.	Bryant	107	Smoking
9-Sep-09	3:08 p.m.	Bryant	N/A	Scheduled Drill
15-Sep-09	8:02 p.m.	Bryant	213	Firecracker
15-Sep-09	10:35 p.m.	Bryant	517A	Smoking
30-Sep-09	7:30 p.m.	Bryant	2nd Floor Kitchen	Burnt Food
6-Oct-09	9:28 a.m.	Bryant	5th Floor	Pull Station Activated
8-Oct-09	10:50 a.m.	Bryant	317	Shower Steam
11-Oct-09	8:05 p.m.	Bryant	3rd Floor	Pull Station Activated
16-Oct-09	3:05 p.m.	Bryant	3rd Floor	Pull Station Activated
24-Oct-09	8:30 p.m.	Bryant	2nd Floor	Pull Station Activated
31-Oct-09	9:55 p.m.	Bryant	3rd Floor	Pull Station Activated
15-Nov-09	10:10 a.m.	Bryant	611	Shower Steam
16-Nov-09	12:00 p.m.	Bryant	3rd Floor	Pull Station Activated
17 Nov 209	9:52 p.m.	Bryant	320	Air Freshner
18-Nov-09	7:35 a.m.	Bryant	512B	Unknown
19-Nov-09	5:20 p.m.	Bryant	211	Shower Steam
1-Dec-09	2:03 a.m.	Bryant	4th Floor	Pull Station Activated

